



# Certificate of Compliance

**Certificate:** 80188894 **Master Contract:** 271907  
**Project:** 80188894 **Date Issued:** 2024-11-29  
**Issued to:** Jiangsu ACREL Electric MFG. Co., Ltd.  
No.5 DongMeng Road, NanZha Street,  
Wuxi, Jiangsu 214405  
China  
**Attention:** Zhonghua Han

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Magnus Chen  
Magnus Chen

## PRODUCTS

Class 3631 06 ELECTRICAL MEASUREMENT AND TEST EQUIPMENT - Electrical Measurement and Test Equipment

Class 3631 86 ELECTRICAL MEASUREMENT AND TEST EQUIPMENT - Certified to US Standards

### **Electric Energy Meter**

Model(s)	Input Voltage (VAC)	Phase	Frequency (Hz)	Category	Input Power (W)
ADL200N-CT	110-240	Single phase	50/60	CAT III	2
ADL400N-CT	L-N: 110-277, L-L: 190-480	Three phase	50/60	CAT III	2

Notes: 1. The above model is permanently connected, Equipment Class II, Pollution Degree 2, Installation/ Measurement Category III.  
2. Mode of operation: Continuous 3. Environmental Conditions: Operating temperature -40 to 70°C, Operating altitude up to 2000m max, Operating humidity 95%RH non-condensation. 4. The main supply cord sets are not provided with the equipment.



**Certificate:** 80188894

**Master Contract:** 271907

**Project:** 80188894

**Date Issued:** 2024-11-29

---

**APPLICABLE REQUIREMENTS**

CAN/CSA C22.2 No. 61010-1-12, UPD1:2015, UPD2:2016, AMD1:2018 - Safety requirements for electrical equipment for measurement, control, and laboratory use — Part 1: General requirements

ANSI/UL 61010-1 3rd Edition (2012), AMD1:2018 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

CSA C22.2 No. 61010-2-030:18 - Safety requirements for electrical equipment for measurement, control, and laboratory use — Part 2-030: Particular requirements for equipment having testing or measuring circuits - Second Edition

UL 61010-2-030, 2nd Edition (2018) - UL Standard for Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use – Part 2-030: Particular Requirements for Equipment Having Testing or Measuring Circuits



**Certificate:** 80188894


**Project:** 80188894

**Master Contract:** 271907

**Date Issued:** 2024-11-29

Notes:

Products certified under Class(es) C363106 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 80188894

**Master Contract:** 271907

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80188894	2024-11-29	The Rail Mounted Electric Energy Meter has no billing function.